

Supplier	TOSHIBA CARRIER CORPORATION
----------	-----------------------------

Indoor unit	RAS-10PKVPG-E
-------------	---------------

Outdoor unit	RAS-10PAVPG-E
--------------	---------------

## Sound power level

indoor unit (cooling)	dB	58
-----------------------	----	----

outdoor unit (cooling)	dB	61
------------------------	----	----

indoor unit (heating)	dB	59
-----------------------	----	----

outdoor unit (heating)	dB	62
------------------------	----	----

## Refrigerant

Type		R32
------	--	-----

Global Warming Potential	kgCO <sub>2</sub> eq	675
--------------------------	----------------------	-----

Refrigerant leakage contributes to climate change. Refrigerant with lower global warming potential (GWP) would contribute less to global warming than a refrigerant with higher GWP, if leaked to the atmosphere. This appliance contains a refrigerant fluid with a GWP equal to 1975. This means that if 1 kg of this refrigerant fluid would be leaked to the atmosphere, the impact on global warming would be 1975 times higher than 1 kg of CO<sub>2</sub>, over a period of 100 years. Never try to interfere with the refrigerant circuit yourself or disassemble the product yourself and always ask a professional.

## Cooling

Energy efficiency class		A+++
-------------------------	--	------

Design load (P <sub>designc</sub> )	kW	2.5
-------------------------------------	----	-----

Seasonal efficiency (SEER)		10.60
----------------------------	--	-------

Seasonal electricity consumption (Q <sub>CE</sub> )	kWh/annum	83
---	-----------	----

## Heating

		Heating/Average	Heating/Warmer	Heating/Colder
Energy efficiency class		A+++	A+++	x
Design load (Pdesignh)	kW	3.0	1.6	x,x
Seasonal efficiency (SCOP)		5.20	6.20	x,xx
Seasonal electricity consumption (Q <sub>HE</sub> )	kWh/annum	807	359	x
Back up heating capacity	kW	0.39		
<b>Declared capacity for heating, at indoor temperature 20°C and outdoor temperature T<sub>j</sub>.</b>				
T <sub>j</sub> = -7°C (Pdh)	kW	2.65	-	x,xx
T <sub>j</sub> = 2°C (Pdh)	kW	1.65	1.65	x,xx
T <sub>j</sub> = 7°C (Pdh)	kW	1.15	1.15	x,xx
T <sub>j</sub> = 12°C (Pdh)	kW	1.28	1.28	x,xx
T <sub>j</sub> =bivalent temperature (Pdh)	kW	2.65	1.65	x,xx
T <sub>j</sub> =operation limit (Pdh)	kW	2.55	2.55	x,xx
T <sub>j</sub> = -15°C (Pdh)	kW	-	-	x,xx